



1 Warner Drive, Springwood Industrial Estate, Braintree, Essex CM7 2YW Contact No. : +44 (0) 1376 335271 Email: sales@sifamtinsley.com www.sifamtinsley.co.uk

c) For serial operation use power supplies of the same type.

d) Earthing of the output is required when the sum of the output voltage is above 60Vdc

e) Keep an installation clearance of 15mm (left / right) between two power supplies on top of each other.

Note : Avoid return voltage (e.g. from a decelerating motor or battery) which is applied to the output terminals.

Power Good Output Function: (Not for Plastic Housing power supplies)

PWR Good

Output is used for preventive function monitoring of the power supply. An electrically isolated signal contact is available. The signal contact closes when output power is OK and Opens when output voltage falls below 20Vdc ± 5%. This feature is particularly useful in redundant applications

Out Voltage				
28 24 20 16 12 8			7	
; 1				
2 open		۹ لا	9	

V-I Characteristics

Max. DC1: 30 Vdc 1 A; Resistive load (EN 60947-4-1)

ACT. 00 Vac TA	
Min.:1mA at 5 Vdc	Min permissive load

Protection:

Power Good Contact rating:

On the primary side: the device is equipped with an internal fuse; follow the next page table. If the internal fuse is blown (fails opens), it is most probable that there is a fault in the device. If this failure occurs, the device must be checked in the factory

12

Caution: in two phase Input models. Double pole / Neutral Fusing. On the secondary side: the devices are electrically protected against:

Over Load, Over Voltage Output (typ.35Vdc), and Short circuit automatically.

Short circuit and overload Protection :

In case of short-circuit or overloading, the output current is interrupted. The device tries again to re-establish output voltage and normal condition repeatedly till the problem is cleared. The output of the device is electrically protected against overload and short circuit. For the nominal voltage and nominal current at temperature condition, please see technical data.

The device can supply at the nominal Current

without switching off. As the overload increases, the output voltage is reduced until zero.

Standards and Certification

Electrical Safety:

Assembling device: IEC/EN 60950 (VDE 0805) and EN 50178 (VDE 0160). Installation according: IEC/EN 60950.

Input / Output separation: SELV EN 60950-1 and PELV EN 60204-1. Double or reinforced insulation.

EMC Standards Immunity:

EN 61000-4-2, EN 61000-4-3, EN 61000-4-4, EN 61000-4-5.


EMC Standards Emission:

EN 61000-6-4, EN 61000-3-2,

Standards Conformity:

Safety of Electrical Equipment Machines: EN 60204-1.


Rail Mounting:



Other models / modules must have a minimum vertical and horizontal distance of 10 cm to this power supply in order to guarantee sufficient auto Addistance of 10 cm to this power supply in order to guarance sumound data
convection. Depending on the ambient temperature and load of the device, the of
temperature of the housing can become very high!

Dimension and Lay-out:

Dimension and Lay-out:



are single output, IP20, have Mounting DIN Rail IEC 60715/TH35. Class 2 isolation for FLEX - e 6024A and Class 1 for FLEX - e 24Volt (With Earth terminal) devices

your application requirements.

.....

are suitable for SELV and PELV soultions. Safety and warning notes WARNING - Explosion Hazard Do not disconnect Equipment unless power has been switched off or the area is known to be non-hazardous.

1, 2 - Phase Power Supplies (24Vdc)

We are certain the Sifam Tinsley INSTRUMENTS Power Supplies will meet

Application

The power supplies FLEX e Series can be used in areas from extreme industrial environment, and complies with the latest technical standard.

Before working with the unit, read these instructions

carefully and completely. All these power supplies

Thank you for having chosen one of our products for your work.

WARNING - Explosion Hazard. Substitution of components may impair suitability for class I, Division 2. WARNING - Switch off the system before connecting the module. Never work on

the machine when it is live. The device must be installed according with UL508. The device must have a suitable isolating facility outside the power supply unit, via which can be switched to idle.

DANGER of fatal injury !!

Connection:

FLEX-C

Cable Connection: The following cable cross-sections may be used:

	Solid (mm ²)	Stranded (mm ²)	AWG	Torque (Nm)	Stripping Length	Power Supply
Input:	0.2 – 2.5	0.2 – 2.5	24 – 14	0.5 – 0.6	7 mm	FLEX- C Series 0.2 -
Output:	0.2 - 2.5	2.5 24 –	14 0.5	–0.6 7ı	nm	FLEX-C Series
Signal:	0.2 – 2.5	0.2 – 2.5	24 – 14	0.5 – 0.6	7 mm	FLEX-C Series

The connection is made by the screw type 2.5 mm (FLEX- Cseries)

terminal block.Use only copper cables that are designed for operating temperatures of > 75 °C. Wiring terminal shall be marked to indicate the proper connection for the power supply.


Input - Output power connection:

Input:			
RISH FLEX- C/Series	1 Phase Switching Powe	er Supplies	L, N
RISH FLEX- C/ Series	1 Phase Switching Powe	er Supplies	L, N, PE 🕀
RISH FLEX- C/ Series	2 Phase Switching Powe	er Supplies	L1, L2, PE 🕀
Output:	24 Vdc is made via the		(+), (-).
1 Phase L N PE	1 Phase L NPE	2	2Phase

Signalling

Red led (Dc ok) status:	Indicates
Lights up permanently	DC Output OK
Switch off	Overload or short circuit
Blink	Overload

Power supplies can be paralleled for 1+1 redundancy to obtain a higher system availability. In Redundant system In case any power supply fails, the other one is automatically able to support the load without any interruption.



This can be done by utilizing decoupling diodes which are included in the Redundancy Module RISH MR220. Recommendations for building redundant power systems:


a) Use separate input fuses for each power supply.

b) Monitor the individual power supply units. A DC-Red led and Power Good Contact are already included on FLEX power supplies. This feature reports a faulty unit; see power Good Section for any technical detail.

c) When possible, connect each power supply to different phases or circuits.

Serial connection:

a) It is possible to connect as many units in series as needed, providing the sum of the output voltage does not exceed 150 Vdc. b) Voltages with a potential above 60Vdc are not SELV any more and can be dangerous. Such voltages must be installed with protection against touching



ling:	
l led (Dc ok) status:	Indicates
nts up permanently	DC Output OK
tch off	Overload or short circuit
k	Overload

Parallel connection Redundancy: