

# Sifam Tinsley Instrumentation Ltd

1 Warner Drive, Springwood Industrial Estate, Braintree, Essex CM7 2YW Contact No. : +44 (0) 1376 335271 Email: sales@sifamtinsley.co.uk

# ELITE 1 Phase (12 Vdc)



Thank you for having chosen one of our products for your work We are certain the Sifam tinsley Elite Series will meet your application requirements.

## **General Description**

Sifam tinsley Elite Series 3612A is a Switch Mode Automatic 3 Stage Battery Charger Suitable for Battery types Open Lead Acid, Sealed Lead Acid, Gel, Ni-Cd.

Sealed Lead Acid, Gel, Ni-Cd. The Battery Charger is used to put energy into a secondary cell or rechargeable battery by forcing an electric current through it. The Battery Charger offers Short circuit, Overload, Over voltage, Reverse Polarity, Over Temperature protections. A rugged casing with bracket for DIN rail mounting provide IP20 protection degree.

# Safety and warning notes

#### WARNINGS :

- WARNINGS : The charger is designed for charging only batteries according to the technical specification.
  Do not use the charger for any other purpose. Always follow battery manufacturers recommendations.
  Never try to charge non rechargeable batteries.
  Check the cables prior to use. Ensure that no cracks have occurred in the cable or bend protection. A charger with damaged cables must not be used.
  Never charge a damaged battery.
  Never charge a frozen battery.
  Never charge a frozen battery.
  Never charge a there on the context when charging.
  Always provide for proper ventilation during charging.
  Always provide for parger.
  A battery being charged could emit explosive gases. Prevent sparks close to the battery.
  Ensure that the cabling does not jam or comes into contact with hot surfaces or sharp edges.

- edges. > Battery acid is corrosive. Rinse immediately with water if acid comes into contact with skin
- or eyes, seek immediate medical advice.
   Never Connect Battery in reverse Polarity.

# **Connection:**

tion. The following cable cross-sections may be used


Cable Connection. The following cable croce cocache may be acca.					
	Solid (mm²)	Stranded (mm <sup>2</sup> )	AWG	Torque (Nm)	Stripping Length
Input:	0.2 – 2.5	0.2 – 2.5	24 – 14	0.5 – 0.6 Nm	7 mm
	4.0	6.0	30 – 10	0.8 – 1.0 Nm	7 mm
Output:	0.2 – 2.5	0.2 – 2.5	24 – 14	0.5 – 0.6 Nm	7 mm
	4.0	6.0	30-10	0.8– 1.0Nm	7 mm
Signal:	0.2 – 2.5	0.2-2.5	24 – 14	0.5 – 0.6 Nm	7 mm
	40	6.0	30 - 10	08-10Nm	7 mm

The Connection is made by the screw type 2.5 mm<sup>2</sup> (ELITE 120XXA series) terminal block. Use only copper cables that are designed for operating temperature of > 75°C wirring terminal shall be marked to indicate the proper connection for the Battery Charger.

Input - Output power connection:

input:		
Elite 3612A Series	1 Phase Switching Battery Charger	L, N, PE 🕀.
Output:	Charging is made via the	(+), (-).


# **Electrical Connection:**



# Signalling:


Description:	LED Status:
Power : Mains OK, Lights up permanently	Green
Charging : Bulk charging, Steady Voltage Charge	
Float : Trickle Charge	Green
Boost Charge : High voltage charge rate to charge the battery (Manual Selection)	
BAT REVERSE/ FUSE BLOWN : Reverse Polarity protection/ Internal Fuse Blown Indication	Red

## **Output Connection:**



MODEL	FUSE RATING		
MODEL	CURRENT	CAPACITY	
ELITE 3612A	5A	350A²s	

# **Operating and Display Elements :**



## No. 1:

The (+) (-) terminals are Output Terminals of battery Charger used to connect battery to battery charger. Ensure that (+) terminal of battery is connected to (+) terminal of charger and (-) terminal of battery is connected to (-) terminal of charger.

#### No. 2:

Boost Charge : Connect (short) Boost Terminal to (+) terminal of battery charger to select Boost mode. Boost charging involves a charging at high voltage than Absorption charge mode to charge the battery. It is generally if the battery has been discharged heavily. Boost charge enables the quick charging of depleted batteries. Thus Charging Battery in Boost charge will take less time to full its Capacity than Normal (Absorption)


Charging. Once battery charger is selected in Boost Charge Mode then it will increased voltage level somewhat higher than Absorption charge voltage level. Thus it deliver high rate of charge at high voltage to full battery capacity

than Absorption charge voltage level. Thus it deliver high rate of charge at high voltage to full pattery capacity rapidly. This mode is helpful to charge battery faster than Absorption Charge mode when battery is heavily discharge. In this mode Charging LED, boost charge LED will Turn ON (Green). Note: Refer Battery manufacturers data sheet for their suggestions on acceptance of higher charge at higher

voltage rates

## No. 3:

Input Terminal of battery charger. Read datasheet carefully for acceptance of input voltage range to Power ON Battery Charger. Refer derating curve of Input versus Battery Capacity (% Load).



# No. 4:

Power: Indicates Mains input is present i.e Battery Charger is Power ON. During Battery Charger is Power ON "Power" LED will light Green.

## No. 5:

CHARGING : The first stage in a three stage charge cycle is known as the bulk charge. In this stage, the battery charger will rapidly return the battery to a state of charge that accomplishes this by maintaining a constant relatively high current. The current is held constant against the rising internal resistance to charge current by raising the battery voltage. When battery is heavily discharge and connected to battery charger, charger will charge it by constant current. During Constant current charging CHARGING LED will be ON (Green). Once battery voltage is raised Charger will reduce charge current to full battery capacity to approx 90%. Refer charging Curve for more detail. detail

### No. 6:

Float : During the float charge, the voltage is dropped to a level lower level than what was applied during the absorption charge. This reduced voltage reduces the possibility of overcharging. The float charge serves two purpose, First, it brings the battery from approx 90 percent state of charge to a 100 percent state of charge. Second, it maintains the battery in a 100 percent state of charge condition. This Mode delivers charges to a battery by tracking it's self discharge rates.

## No. 7:

BAT REVERSE/ FUSE BLOWN : If Battery is connected in reverse polarity then Battery charger will protect it

BAT REVERSE/FUSE BLOWN : If Battery is connected in reverse polarity then Battery charger and Battery in safe mode. by disconnecting charger to keep Battery charger and Battery in safe mode. The Internal fuse will blown up immediately when connected in reverse polarity. BAT REVERSE/FUSE BLOWN will turn ON (RED) when battery is connected in reverse polarity or if the internal fuse of the battery charger is blown. To use battery charger for normal operation replace the blow fuse as per rating of fuse depending upon the battery charger model. For 3612A fuse rating specifications are: FAST ACTING FUSE 250V AC 5A 20X5mm Warning: - Avoid Reverse Polarity Connection of Battery to Charger. the blown

# No. 8:



RELAY CONTACT Battery Charger is having an electrically isolated Signal contact (Relay Output). The Signal Contact closes when output Power is OK (NO, COM will make contact) and Opens either in absence of input voltage or some internal fault (NC, COM will make contact). The Symbol of Relay Contacts are as shown. One can use this feature as Alarm output to indicate that Battery Charger is failed and look at input supply voltage. This feature is particularly useful in redundant application.


### Charge Fail Contact Rating:

Max, DC1: 30 Vdc1 A; Resistive load (EN 60947-4-1) AC1: 120 Vac1A Min:1mA at 5 Vdc Min permissive load

# **Standards and Certification**

Standards and Certification
Norms and certifications
The CE mark in According to EMC 2004/108/EC and Low voltage directive 2006/95/EC.
Electrical Safety
According to IEC/EN 60950 (VDE 0805) EN 50178 (VDE 0160) for assembling device. The unit must be
installed according to IEC/EN 60950. Input / Output separation: SELV EN60950-1 and PELV EN 60204-1.
Double or reinforced insulation.
EMC Immunity
EN 61000-4-2, EN 61000-3-2, EN 61000-4-4, EN 61000-4-5, EN 61000-4-6, EN61000-6-2
EMC Emission
EN61000-6-4, EN 61000-3-2
Standards Conformity
EN 60204-1 Safety of Electrical Equipment Machines.

# Rail Mounting:



Other models / modules must have a minimum vertical and horizontal distance of 100mm to this power supply in order to guarantee sufficient auto convection. Depending on the ambient temperature and load of the device, the temperature of the housing can become very high!



Sifam Tinsley Instrumentation Ltd 1 Warner Drive, Springwood Industrial Estate, Braintree, Essex CM7 2YW Contact No. : +44 (0) 1376 335271 Email: sales@sifamtinsley.com www.sifamtinsley.co.uk